



DESIGN NOTES

1. SPECIAL DESIGN CONSIDERATION OR STRUCTURAL REVIEW MAY BE REQUIRED FOR LONGER FACILITY EDGE SPANS. STEEL REINFORCEMENT OR ADDITIONAL CONCRETE CHECK DAMS MAY BE NEEDED FOR STABILITY.
2. EDGE CONDITION WILL VARY FOR PROJECTS. CURB DETAILS MAY BE MODIFIED BY CIVIL AND GEOTECHNICAL ENGINEERS AND APPROVED BY PUBLIC WORKS DEPARTMENT.
3. CONCRETE AND EXPANSION JOINTS SHALL MEET THE REQUIREMENTS OF THE CITY OF NAPA.
4. FINISHED ELEVATION REVEAL AT SIDEWALK - WHERE SIDEWALK CONVEYS SHEET FLOW TO FACILITY, A 1"-2" REVEAL SHOULD BE MAINTAINED BETWEEN SIDEWALK AND FACILITY FINISHED GRADE TO AVOID MULCH OR PLANT BUILDUP FROM BLOCKING FLOWS AND REDUCE DROP AT PEDESTRIAN INTERFACE.

CONSTRUCTION NOTES

1. FINISH ALL EXPOSED CONCRETE SURFACES.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

FLUSH CURB AT SIDEWALK

DRAWN BY:	LFM
DATE:	06/2018
SCALE:	NONE
FIELD NOTES:	

CHECKED BY:	TCW
APPROVED BY:	JRL
DRAWING NO.	SWQ-113