



NOTES

1. THE USE OF NON-EPOXY COATED FITTINGS AS AN ALTERNATE MATERIAL TO EPOXY COATED FITTINGS MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. THE ANODE SHALL BE INSTALLED VERTICALLY OR HORIZONTALLY WITH THE TOP OF THE ANODE 5 FT BELOW GRADE AND 3 FT BELOW PIPE.

CITY OF NAPA

UTILITIES DEPARTMENT

TITLE
VERTICAL OFFSETS - ANODE INSTALLATION

DRAWN BY: DF
 APPROVAL DATE: 09/2021
 SCALE: NTS
 REVISED DATE: 09/2021

CHECKED BY: SL
 APPROVED BY: DD
 DRAWING NO. W-24C