



NOTES:

1. THE USE OF NON-METALLIC PIPE AS AN ALTERNATE MATERIAL TO DUCTILE IRON MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. THE ANODE SHALL BE INSTALLED VERTICALLY OR HORIZONTALLY WITH THE TOP OF THE ANODE 5 FT. BELOW GRADE AND 3 FEET BELOW PIPE.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

TITLE

VERTICAL OFFSETS - ANODE INSTALLATION

DRAWN BY: DCF

DATE: 07/2017

SCALE: NTS

FIELD NOTES:

CHECKED BY: MJH

APPROVED BY: MJH

DRAWING NO.

W-24C