



NOTES:

1. FPTS REQUIRE PRIOR APPROVAL FROM WATER DIVISION. NUMBER AND SIZE OF ANODES SHALL BE DETERMINED BY THE PROJECT ENGINEER.
2. IDENTIFY CABLES PER DRAWING W-26C.
3. INSTALL THE REFERENCE CELL BETWEEN THE TWO PIPELINES.
4. PERMISSION MUST BE OBTAINED FROM THE FOREIGN PIPELINE OWNER PRIOR TO ATTACHMENT OF TEST WIRES.

CITY OF NAPA

UTILITIES DEPARTMENT

TITLE
FOREIGN PIPELINE TEST STATION

DRAWN BY: DF
 APPROVAL DATE: 09/2021
 SCALE: NTS
 REVISED DATE: 09/2021

CHECKED BY: SL
 APPROVED BY: DD
 DRAWING NO. W-27B