



NOTES:

1. NUMBER AND SIZE OF ANODES SHALL BE DETERMINED BY THE PROJECT CORROSION ENGINEER.
2. IDENTIFY CABLES PER DRAWING W-26C.
3. INSTALL THE REFERENCE CELL BETWEEN THE TWO PIPELINES.
4. PERMISSION MUST BE OBTAINED FROM THE FOREIGN PIPELINE OWNER PRIOR TO ATTACHMENT OF TEST WIRES.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

TITLE
FPTS - FOREIGN PIPELINE TEST STATION

DRAWN BY: DCF

CHECKED BY: MJH

DATE: 07/2017

APPROVED BY: MJH

SCALE: NTS

DRAWING NO.

FIELD NOTES:

W-27B