



**NOTES:**

1. INSTALL ANODE A MINIMUM OF 3-FEET FROM VALVE.
2. IDENTIFY CABLES PER DRAWING W-26C.

CITY OF NAPA

UTILITIES DEPARTMENT

TITLE  
VALVE - ANODE TEST STATION

DRAWN BY: DF  
 APPROVAL DATE: 09/2021  
 SCALE: NTS  
 REVISED DATE: 09/2021

CHECKED BY: SL  
 APPROVED BY: DD  
 DRAWING NO.  
 W-28C