



NOTES

1. TRENCHES MADE WITHIN 5' PARALLEL TO AN EXISTING GUTTER OR EDGE OF ROAD WILL REQUIRE REMOVAL AND REPLACEMENT OF EXISTING AC PAVING TO EDGE.
2. IF UTILITY CONFLICTS REQUIRE OFFSET OF NEW OR EXISTING WATER MAINS OR WATER SERVICES, WATER FACILITIES SHALL NOT BE INSTALLED WITH LESS THAN 2-FOOT COVER.
3. POTHOLES SHALL BE BACKFILLED WITH CONTROLLED DENSITY FILL INSTEAD OF CLASS II AGGREGATE BASE. A CLEAN WASHED UTILITY SAND SHALL STILL BE REPLACED BACK OVER WATER MAIN AS SHOWN.
4. TRENCH PLATES PLACED ON ARTERIAL OR HEAVILY TRAVELED ROADWAYS MUST BE RECESSED. CONTACT CITY OF NAPA PUBLIC WORKS FOR STREET CLASSIFICATIONS.

CITY OF NAPA

UTILITIES DEPARTMENT

TITLE

WATER TRENCH DETAIL

DRAWN BY: DF
 APPROVAL DATE: 09/2021
 SCALE: NTS
 REVISED DATE: 09/2021

CHECKED BY: SL
 APPROVED BY: DD
 DRAWING NO. W-13A