



NOTES

1. SERVICE LINE SHALL BE INSTALLED OUTSIDE OF DRIVEWAYS AND DRIVEWAY APPROACHES.
2. NO TREES SHALL BE PLANTED WITHIN 10', OR LARGE SHRUBS WITHIN 5', OF THE SERVICE LATERAL. SEE W-18 FOR ADDITIONAL CONSTRUCTION REQUIREMENTS.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

TITLE
**WATER SERVICE MAINTENANCE
 RESPONSIBILITY (FIRE SERVICE)**

DRAWN BY: DCF
 DATE: 07/2017
 SCALE: NTS
 FIELD NOTES:

CHECKED BY: MJH
 APPROVED BY: MJH
 DRAWING NO. W-20B