



**NOTES:**

1. WELDED WIRE MESH SHALL BE #6 T304 STAINLESS STEEL WIRE MESH AND SHALL BE INSTALLED UNDER BOX, WASHED GRAVEL AND AROUND 8" SCH 40 PVC PIPE.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

GATE VALVE

DRAWN BY: BRL

CHECKED BY: DMP

DATE: 06/2018

APPROVED BY: JRL

SCALE: NONE

DRAWING NO.

FIELD NOTES:

PL-6