




STANDARD CURB & 24" GUTTER



NOTE:
EDGER FINISH ALL EXPANSION &
WEAK PLANE JOINTS. SLIP
DOWELS INSTALLED AT ALL
EXPANSION JOINTS



TYP. EXPANSION JOINT



TYP. WEAK PLANE JOINT

NOTES

1. ALL CURBS ON PRIVATE STREETS AND PARKING LOTS SHALL BE TO CITY STANDARDS.
2. ALL CONCRETE SHALL BE 4000 PSI (6 SACKS PER CUBIC YARD), 3/4" AGGREGATE.
3. CONCRETE SHALL BE BRUSH FINISHED PARALLEL TO FACE OF CURB.
4. ALL CURBS SHALL BE BACKFILLED BEFORE STREET IS ROCKED & PAVED.
5. CLASS 2 AGGREGATE BASEROCK, SUBGRADE & FILL MATERIAL IF ANY SHALL HAVE A MINIMUM OF 95% RELATIVE COMPACTION UNDER CURB & GUTTER.
6. ON STRAIGHT RUN OF STD. CURB & GUTTER, 1/2" EXPANSION JOINTS. SHALL BE INSTALLED AT 40' OC, & WEAK PLANE JOINTS. INSTALLED MIDWAY BETWEEN EXPANSION JOINTS.
7. FOR EXPANSION JOINTS & WEAK PLANE JOINTS AT CURB RETURNS SEE CITY STD. S-8 & S-9. FOR EXPANSION JOINTS & WEAK PLANE JOINTS AT CATCH BASINS SEE CITY STD. D-2.
8. SUBGRADE AND CLASS 2 A.B. SHALL EXTEND TO ONE FOOT BEHIND CURB AND GUTTER.
9. EXTRUDED CURB AND GUTTER SHALL HAVE WEAK PLANE JOINTS AT 12' ON CENTER.
10. UTILITY IDENTIFICATION SYMBOLS ("S" FOR SANITARY SEWER AND "W" FOR WATER UTILITIES) SHALL BE STAMPED WHERE UNDERLYING UTILITIES ARE IDENTIFIED. SYMBOLS SHALL BE 1/8" DEEP, 3" HIGH PLACE ON TOP OF CURB AND FACE OF CURB.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

STANDARD CURB & GUTTER

DRAWN BY: BRL

CHECKED BY: JGF

DATE: 06/2018

APPROVED BY: JRL

SCALE: NONE

DRAWING NO.

FIELD NOTES:

S-1