



NOTES

1. ALL CONCRETE TO BE 4000 PSI (6 SACK/CY).
2. SEE CITY STD S-4B, CONCRETE CONNECTION DETAIL.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

STANDARD P.C.C.
CROSS GUTTER

DRAWN BY:	BRL
DATE:	06/2018
SCALE:	NONE
FIELD NOTES:	

CHECKED BY:	JGF
APPROVED BY:	JRL
DRAWING NO.	S-11A