



DESIGN NOTES

1. SPECIAL DESIGN CONSIDERATION OR STRUCTURAL REVIEW MAY BE REQUIRED FOR LONGER FACILITY EDGE SPANS. STEEL REINFORCEMENT OR ADDITIONAL CONCRETE CHECK DAMS MAY BE NEEDED FOR STABILITY.
3. FINISHED ELEVATION REVEAL - WHERE SIDEWALK CONVEYS SHEET FLOW TO FACILITY, A 1"-2" REVEAL SHOULD BE MAINTAINED BETWEEN SIDEWALK AND FACILITY FINISHED GRADE TO AVOID MULCH OR PLANT BUILDUP FROM BLOCKING FLOWS.
4. CONCRETE AND EXPANSION JOINTS SHALL MEET THE REQUIREMENTS OF THE CITY OF NAPA.

CONSTRUCTION NOTES

1. FINISH ALL EXPOSED CONCRETE SURFACES.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

THICKENED EDGE SIDEWALK

DRAWN BY:	LFM
APPROVAL DATE:	06/2018
SCALE:	NONE
REVISED DATE:	

CHECKED BY:	TCW
APPROVED BY:	JBL
DRAWING NO.	SWQ-112