

NOTES

1. STREET LIGHT POLES AND MAST ARMS SHALL BE TYPE 15 PER OCT 30, 2015 CALTRANS STANDARD PLANS AND SPECIFICATIONS DRAWING ES-6A. SPLICING SHALL BE PER OCT 30, 2015 CALTRANS STANDARD PLANS AND SPECIFICATIONS DRAWING ES-13A.
2. STREET LIGHT POLE FOUNDATIONS, BOLTS, AND REINFORCEMENT CAGES SHALL BE PER OCT 30, 2015 CALTRANS STANDARD PLANS AND SPECIFICATIONS DRAWING ES-7N. CAGES DO NOT REQUIRE WELDING.
3. STREET LIGHT LOCATIONS SHALL BE SHOWN ON IMPROVEMENT PLANS, POLE SPACING SHALL BE PROVIDED BY CITY OF NAPA ELECTRICAL DIVISION.
4. DEVELOPER SHALL CONTACT PG&E TO ESTABLISH STREET LIGHT SERVICE LOCATIONS, THEN PROVIDE CITY OF NAPA PUBLIC WORKS DEPARTMENT WITH SAME LOCATIONS, IN ACCORDANCE WITH THE LS2A RATE SCHEDULE.
5. LED FIXTURE SIZE MAY BE INCREASED ON COLLECTOR AND ARTERIAL STREETS OR AS OTHERWISE DETERMINED BY THE CITY OF NAPA ELECTRICAL DIVISION.
6. STREET LIGHT FIXTURE SHALL BE 120 VOLT LED CREE COBRA HEAD WITH TWIST LOCK PHOTO ELECTRIC CONTROL RECEPTACLE ON TOP. REFER TO IMPROVEMENT PLANS FOR SIZE.
7. PHOTO ELECTRIC CONTROL SHALL BE FISHER-PIERCE ELL-124.
8. STREET LIGHT WIRE FROM PULL BOX TO FIXTURE SHALL BE #10 THHN SOLID OR #10 THW STRANDED (TS) WIRE.
9. ALL FIELD WIRING SHALL BE #8 THHN OR THW STRANDED.
10. BOND WIRE SHALL BE CONNECTED TO ALL POLES AND GROUND RODS IN THE SYSTEM.
11. INSTALL 1/2" x 8' COPPER CLAD GROUND ROD IN CENTER OF EACH FOUNDATION.
12. THERE SHALL BE NO SPLICES IN POLE BASE.
13. ALL CONDUITS SHALL BE 24" DEEP IN THE CLEAR FROM FINISH GRADE, 2" SAND BED, 12" MINIMUM SAND COVER.
14. PULL BOXES SHALL BE PLACED NEXT TO EACH STREET LIGHT AND AT PG&E SECONDARY BOX LOCATIONS THAT FEED STREET LIGHTS. ADDITIONAL PULL BOXES SHALL BE INSTALLED IN CONDUIT RUNS EXCEEDING 200' OR AS OTHERWISE DIRECTED BY THE ENGINEER. BOX LIDS SHALL BE MARKED "STREET LIGHTING" AND SHALL HAVE HOLD DOWN BOLTS.
15. IN UNDEVELOPED AREAS CONSTRUCT A 30"x30" CONC. PAD (4" THICK). IF A ROUND FOOTING IS POURED, STOP AT THE ELEVATION OF THE BOTTOM OF THE SIDEWALK.
16. DUE TO POSSIBLE CONFLICTING UTILITIES, STREET LIGHTS ARE SUBJECT TO RELOCATION WITH CITY OF NAPA ELECTRICAL DIVISION APPROVAL.
17. COBRA HEAD MODEL NUMBERS SHALL BE LISTED ON THE IMPROVEMENT PLANS.
18. IT IS THE RESPONSIBILITY OF THE DEVELOPER OR THEIR REPRESENTATIVE TO CONTACT THE MANUFACTURER FOR THE LATEST MODEL NUMBERS/TYPES.
19. THE CONTRACTOR SHALL BE RESPONSIBLE TO CALL U.S.A (811) AT LEAST 2 WORKING DAYS PRIOR TO ANY EARTHWORK.
20. CONTACT CITY OF NAPA ELECTRICAL DIVISION AT (707) 257-9588 FOR INSPECTION 24 HOURS PRIOR TO POURING CONCRETE AND/OR BACKFILLING CONDUIT. CONTACT CITY OF NAPA ELECTRICAL DIVISION FOR FINAL INSPECTION AND TURN-ON.
21. ALL CONDUIT SHALL BE SEALED WITH APPROVED DUCT SEAL. CONDUITS FOR FUTURE EXTENSIONS SHALL BE CAPPED WITH CONDUIT PLUGS.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

STANDARD RESIDENTIAL
STREET LIGHT - NOTES

| | | | |
|----------------|---------|--------------|-----|
| DRAWN BY: | BRL | CHECKED BY: | SEC |
| APPROVAL DATE: | 06/2018 | APPROVED BY: | JRL |
| SCALE: | NONE | DRAWING NO. | E-2 |
| REVISED DATE: | 10/2020 | | |