



NOTES

1. TRENCHES MADE WITHIN 5' PARALLEL TO AN EXISTING GUTTER OR EDGE OF ROAD WILL REQUIRE REMOVAL AND REPLACEMENT OF EXISTING AC PAVING TO EDGE.
2. IF UTILITY CONFLICTS REQUIRE OFFSET OF NEW OR EXISTING WATER MAINS OR WATER SERVICES, WATER FACILITIES SHALL NOT BE INSTALLED WITH LESS THAN 2-FOOT COVER.
3. POTHOLES SHALL BE BACKFILLED WITH CONTROLLED DENSITY FILL INSTEAD OF CLASS II AGGREGATE BASE. SAND BEDDING SHALL STILL BE REPLACED BACK OVER WATER MAIN AS SHOWN.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

TITLE
WATER TRENCH DETAIL

DRAWN BY: DCF

CHECKED BY: MJH

DATE: 07/2017

APPROVED BY: MJH

SCALE: NTS

DRAWING NO.

FIELD NOTES:

W-13A