



NOTES

PROFILE

1. HOT-TAPS REQUIRED WHEN NEW MAINS OR SERVICE LATERALS ARE CONNECTED TO EXISTING WATER MAINS. ALL HOT TAPS SHALL BE BY CITY FORCES AT THE CONTRACTOR'S EXPENSE.
2. CONTRACTOR SHALL PROVIDE SAWCUTTING, EXCAVATION, BACKFILL, COMPACTION, PLATING, PAVING, TRAFFIC CONTROL, AND ENCROACHMENT PERMIT.
3. CONTRACTOR SHALL PROVIDE AND INSTALL SHORING PER OSHA STANDARDS.
4. THE CONTRACTOR SHALL MODIFY SITE CONDITIONS TO THE SATISFACTION OF THE CITY REPRESENTATIVE.
5. HOT-TAP SHALL BE INSTALLED 24" MIN. FROM ANY TAP, BELL, FITTING, WATER SERVICE, ETC.
6. FOR 1" HOT-TAPS, 7' DIMENSION CAN BE REDUCED TO 5'.
7. FEES SHALL BE PAID AT THE WATER DIVISION OFFICE LOCATED AT 1340 CLAY ST. FOR QUESTIONS REGARDING FEES, CALL (707) 257-9521.
8. AFTER FEES HAVE BEEN PAID, ALLOW 7 TO 10 WORKING DAYS FOR SCHEDULING HOT-TAP INSTALLATION.
9. TO SCHEDULE A HOT-TAP AFTER FEES HAVE BEEN PAID, CALL (707) 257-9544.
10. IF EXISTING UTILITIES EXIST WITHIN THE HOT TAP EXCAVATION PIT AND INHIBIT CITY CREWS FROM COMPLETING HOT TAP, CONTRACTOR MAY BE REQUIRED TO MODIFY EXISTING WATER MAIN, TO CUT IN NEW TEE FOR WATER SERVICE, OR RELOCATE EXISTING UTILITIES. MODIFICATIONS TO WATER FACILITIES SHALL BE DETERMINED BY WATER DIVISION STAFF.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

TITLE
HOT-TAP DETAIL

DRAWN BY:	DCF	CHECKED BY:	MJH
DATE:	07/2017	APPROVED BY:	MJH
SCALE:	NTS	DRAWING NO.	W-16A
FIELD NOTES:			