



NOTES:

1. THE USE OF NON-EPOXY COATED FITTINGS AS AN ALTERNATE MATERIAL TO EPOXY COATED FITTINGS MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. THIS DETAIL IS TYPICAL OF ELBOWS, REDUCERS & OTHER FITTINGS.
3. MULTIPLE FITTINGS MAY BE BONDED TOGETHER AND PROTECTED WITH ONE ANODE PER DRAWING W-23A.
4. NO TEST STATION IS REQUIRED FOR ELBOWS, REDUCERS & OTHER FITTINGS, HOWEVER A RECORD OF ALL INSTALLATIONS SHALL BE PROVIDED TO THE PROJECT ENGINEER.

CITY OF NAPA

UTILITIES DEPARTMENT

<p>TITLE</p> <p>FITTING - ANODE INSTALLATION</p>	<p>DRAWN BY: DF</p>	<p>CHECKED BY: SL</p>
	<p>APPROVAL DATE: 09/2021</p>	<p>APPROVED BY: DD</p>
	<p>SCALE: NTS</p>	<p>DRAWING NO.</p>
	<p>REVISED DATE: 09/2021</p>	<p>W-24B</p>