



**NOTES:**

1. THE USE OF NON-METALLIC PIPE AS AN ALTERNATE MATERIAL TO DUCTILE IRON MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. THIS DETAIL IS TYPICAL OF ELBOWS, REDUCERS & OTHER FITTINGS.
3. MULTIPLE FITTINGS MAY BE BONDED TOGETHER AND PROTECTED WITH ONE ANODE PER DRAWING W-25C.
4. NO TEST STATION IS REQUIRED FOR THESE FITTINGS, HOWEVER A RECORD OF ALL INSTALLATIONS SHALL BE PROVIDED TO THE PROJECT ENGINEER.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

TITLE  
FITTING - ANODE INSTALLATION

DRAWN BY: DCF

CHECKED BY: MJH

DATE: 07/2017

APPROVED BY: MJH

SCALE: NTS

DRAWING NO.

FIELD NOTES:

W-24B