



- NOTES**
1. WELDED WIRE MESH SHALL BE #6 T304 STAINLESS STEEL WIRE MESH AND SHALL BE INSTALLED UNDER BOX, WASHED GRAVEL AND AROUND 8" SCH 40 PVC PIPE.
 2. GATE VALVE: THREE INCHES AND SMALLER SHALL BE NIBCO T-113 OR APPROVED EQUAL. FOUR INCHES AND LARGER SHALL BE NIBCO F-160-RW SERIES AS SPECIFIED.

CITY OF NAPA

PARKS & RECREATION SERVICES DEPARTMENT

GATE VALVE

DRAWN BY:	BRL	CHECKED BY:	DMP
APPROVAL DATE:	06/2018	APPROVED BY:	JRL
SCALE:	NONE	DRAWING NO.	PL-6
REVISED DATE:	08/2021		