



**ALTERNATE MATERIALS MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE**

**ALL INTERIOR RESTRAINTS, SUPPORTS, SEISMIC PROTECTION, AND DRAINAGE FOR THE BACKFLOW DEVICE SHALL MEET THE CURRENT CALIFORNIA BUILDING AND PLUMBING CODES**

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

TITLE **INTERIOR DOUBLE CHECK VALVE  
BACKFLOW DEVICE INSTALLATION FOR  
2" FIRE WATER SERVICES**

DRAWN BY:	DCF
DATE:	07/2017
SCALE:	NTS
FIELD NOTES:	

CHECKED BY:	MJH
APPROVED BY:	MJH
DRAWING NO.	W-7B.1