



## Waterline and Underground Flush Checklist

- Contractor to provide a written scope of work detailing method(s) used to discharge potable water
- If discharging potable water to the City's MS4 system identify which storm drain inlet(s) will be used and the water's path of travel
- Identify disposal method:
  - landscaped or vegetated area
  - Sanitary sewer system (prior approval from Napa Sanitation District required)
  - City of Napa MS4 system
  - Collection for reuse
  
- Water is dechlorinated prior to discharge
  - Provide method of dechlorination:  

---

---
  
- pH level is between 6.5 and 8.5
  
- Water is free of any unusual coloration, dirt, suds, and algae
- Path of travel is free of any dirt and debris
- Inlet protection is in place prior to discharging to the City's MS4 system
- If discharging to vegetation, land area is sufficient to prevent erosion and runoff into a waterbody
- Notify the Stormwater Program, Fire and Water Departments prior to performing the flush. Estimated date of flush \_\_\_\_\_.

Contractor: \_\_\_\_\_  
*Signature*

City Staff: \_\_\_\_\_  
*Signature*

Date: \_\_\_\_\_

Date: \_\_\_\_\_

Any questions please contact Stephanie Proft with the Stormwater Program at:

707-258-7840 or [sproft@cityofnapa.org](mailto:sproft@cityofnapa.org)

Rev 4/19