



NOTES

1. OWNER SHALL BE RESPONSIBLE FOR CLEANING AND MAINTAINING DRAIN PIPE ON BOTH HIS PROPERTY AND THE PORTION THROUGH THE SIDEWALK.
2. 10-GAUGE WIRE MESH 4" X 4". WIRE MESH SHALL BE FULL WIDTH OF SIDEWALK MINUS 2". LENGTH OF WIRE MESH SHALL AT A MINIMUM EQUAL THE WIDTH AND SHALL BE CENTERED OVER PIPE. WIRE MESH SHALL BE PLACED MID-WAY BETWEEN THE BOTTOM OF THE WEAKENED PLANE JOINTS AND THE TOP OF THE PIPE(S).
3. MULTIPLE PIPES MAY BE USED WHERE NECESSITATED BY THE CONTRIBUTING AREA. IN THIS CASE PIPES SHALL BE SPACED 6" ON CENTER.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

RESIDENTIAL UNDER
SIDEWALK DRAIN

DRAWN BY: LFM
 APPROVAL DATE: 06/2018
 SCALE: NONE
 REVISED DATE: 08/2021

CHECKED BY: IHH
 APPROVED BY: JBL
 DRAWING NO. D-5A