



Fire & Life Safety Common Violations



CHECK AND TEST ALL SMOKE DETECTORS



CHECK AND TEST ALL CARBON MONOXIDES DETECTORS




CHECK ALL ELECTRICAL CORDS




ANNUALLY SERVICE ALL FIRE EXTINGUISHERS



CHECK WATER HEATER STRAPS/ KEEP 3 FEET FROM ANY COMBUSTIBLE STORAGE



KEEP ALL EXIT WAYS AND DOORS FREE OF OBSTRUCTIONS OR STORAGE



REPAIR HOLES OR PENETRATIONS



UPDATE EMERGENCY CONTACTS AND EVACUATION MAP