



Fire Extinguisher's



Visibly mount on walls with the hangers or brackets supplied.

Fire Extinguishers shall be installed so that the carrying handle of the extinguisher is not more than 5' above the floor.



Each fire extinguisher shall be serviced annually as required and shall have an annual maintenance tag.



Fire extinguisher(s) with a minimum 2-A:10-B:C classification rating to serve each floor level.

Locate fire extinguishers in conspicuous locations where they are readily accessible and immediately available for use.