



NOTES

1. SIGNS SHALL BE RED ON WHITE REFLECTIVE COMMERCIAL GRADE 0.08 GAUGE.
2. SIGNS SHALL BE VISIBLE AND READABLE ALONG ACCESS ROADWAY.
3. SIGNS ARE TO FACE ONCOMING TRAFFIC.
4. SIGNS ARE TO BE MAINTAINED BY THE PROPERTY OWNER.
5. A MINIMUM OF ONE SIGN SHALL BE POSTED AT THE BEGINNING AND END OF THE FIRE LANE AREA.
6. FOR CONTINUOUS FIRE LANES AREAS, SIGNS SHALL BE POSTED AT INTERVALS OF 100' MINIMUM AND 175' MAXIMUM.
7. SIGNS ARE TO BE POSTED SO THE BOTTOM OF THE SIGN IS 90" ABOVE GROUND LEVEL.
8. SIGN POSTS SHALL BE LOCATED 2' FROM EDGE OF TRAVELED WAY TO CENTER OF POST.
9. FINAL PLACEMENT OF ALL SIGNS SHALL BE SUBJECT TO THE APPROVAL OF THE FIRE CODE OFFICIAL.

CITY OF NAPA

FIRE DEPARTMENT

FIRE LANE SIGN & PLACEMENT

DRAWN BY: LFM
 APPROVAL DATE: 08/2021
 SCALE: NONE
 REVISED DATE:

CHECKED BY: BV
 APPROVED BY: GDF
 DRAWING NO. FP-2