





FIRE LANE SIGN "B"  
 RED ON WHITE REFLECTIVE COMMERCIAL  
 GRADE 0.080 GAUGE



**NOTES**

1. SIGNS SHALL BE VISIBLE AND READABLE ALONG ACCESS ROADWAY.
2. SIGNS ARE TO FACE ONCOMING TRAFFIC AT ALL POINTS OF ENTRY TO THE PROPERTY.
3. SIGNS AND CURBS ARE TO BE MAINTAINED BY THE PROPERTY OWNER.
4. SIGNS ARE TO BE POSTED SO THE BOTTOM OF THE SIGN IS 90" ABOVE GROUND LEVEL.
5. ALL CURBS ALONG FIRE LANES ARE REQUIRED TO BE PAINTED RED AND STENCILED "FIRE LANE NO PARKING".
6. SIGN POSTS SHALL BE LOCATED 2' FROM EDGE OF TRAVELED WAY TO CENTER OF POST.
7. THERE SHALL BE A MAXIMUM DISTANCE OF 20' BETWEEN "FIRE LANE NO PARKING" LETTERING.
8. IF NO CURBS ARE PRESENT, CONTINUOUS RED STRIPING OF 6" WIDTH SHALL BE USED, LETTERING IS THE SAME AS CURBS.
9. LETTERING ON CURBS IS TO BE A MINIMUM OF 3" IN HEIGHT AND WHITE IN COLOR.

CITY OF NAPA

PUBLIC WORKS DEPARTMENT

**FIRE LANE SIGN &  
 CURB MARKING STANDARD**

DRAWN BY: LFM  
 DATE: 06/2018  
 SCALE: NONE  
 FIELD NOTES:

CHECKED BY: GDF  
 APPROVED BY: JRL  
 DRAWING NO. FP-2B