



- NOTES:
- HAVE KEY(S) MADE THAT WILL PROVIDE ACCESS TO THE INTERIOR OF THE BUILDING, ANY INTERIOR SECURED AREAS AND ANY SPECIFIC KEYS REQUESTED BY THE FIRE DEPARTMENT.
 - THE KEY BOX SHALL BE INSTALLED NO LOWER THAN 5' FROM THE BOTTOM OF THE KEY BOX AND NO HIGHER THAN 6' FROM THE TOP OF THE KEY BOX ABOVE FINISHED GRADE. KEY BOX SHALL BE NO GREATER THAN 10' ADJACENT TO THE MAIN BUILDING ENTRANCE THAT FRONTS THE PUBLIC STREET ACCESS UNLESS DESIGNATED AT A DIFFERENT LOCATION BY THE FIRE DEPARTMENT.
 - THE BOX MUST BE INSTALLED IN PLAIN VIEW, AS YOU APPROACH THE BUILDING, IN A LOCATION NOT LIKELY TO BE HIDDEN WITH LANDSCAPE GROWTH OR OTHER OBSTRUCTIONS.
 - FOLLOW THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.
 - ALL KEYS MUST BE LABELED USING A SUBSTANTIAL KEY IDENTIFICATION TAG THAT WILL WITHSTAND EXPOSURE TO MOISTURE.
 - TEST ALL KEYS IN LOCK MECHANISMS BEFORE CONTACTING THE FIRE PREVENTION DIVISION.
 - SCHEDULE AN INSPECTION ON THE FIRE PREVENTION DIVISION WEB PAGE TO HAVE THE KEY BOX LOCKED.

CITY OF NAPA

FIRE DEPARTMENT

KNOX BOX MOUNTING HEIGHT

DRAWN BY:	RC	CHECKED BY:	BV
APPROVAL DATE:	08/2021	APPROVED BY:	GDF
SCALE:	NONE	DRAWING NO.	FP-13
REVISED DATE:			