



NOTES:

1. ALL UTILITY ROOMS AND RELATED FIRE APPURTENANCES SHALL BE LABELED AND BE PROPERLY IDENTIFIED AS TO THE PURPOSE THEY SERVE.
2. SIGNAGE AT HVAC, SPRINKLER, ELECTRICAL, AND FIRE ALARM CONTROL PANEL LOCATION.
3. ALL REQUIRED SIGNS SHALL BE WEATHER RESISTANT AND PERMANENTLY AFFIXED.
4. IN UTILITY ROOMS OR OTHER AREAS WHERE COMBUSTIBLE STORAGE IS NOT ALLOWED, A PERMANENTLY AFFIXED SIGN SHALL BE INSTALLED THAT READS, "NO STORAGE PERMITTED BY ORDER OF FIRE MARSHAL".

CITY OF NAPA

FIRE DEPARTMENT

SIGNAGE DETAILS

DRAWN BY:	RC	CHECKED BY:	BV
APPROVAL DATE:	08/2021	APPROVED BY:	GDF
SCALE:	NONE	DRAWING NO.	FP-16
REVISED DATE:			